



Request for Qualifications – P.W. 464-8
City of Antioch Water Treatment Plant
SCADA and Information System Advisory Specialist

Addendum No. 1

August 5, 2025

**City of Antioch Water Treatment Plant
SCADA and Information System Advisory Specialist — Questions and Answers**

Q. What number of assets does the City have that are connected to the Water Treatment Plant? Wells, pumps, reservoirs, etc.

A. There are multiple assets at the Water Treatment Plant as well as approximately 20 offsite assets.

Q. What PLC manufacturer does the City use?

A. We have multiple PLC's, mostly Modicon & Schneider.

Q. What SCADA software does the City use?

A. Aveva.

Q. Does the City use any auxiliary software for reporting, alarms, historizing, etc.?

A. Yes.

Q. Will the System Advisory Specialist also be allowed to perform integration work, or is the position limited to consulting only?

A. The consultant will be able to perform integration work as needed/necessary.

This addendum must be included with your bid:

Company Name _____

Date Received _____

Signature _____

Name _____

Title _____