



**SUPPLEMENTAL INFORMATION
TO
REQUEST FOR PROPOSALS**

**FOR THE INTEGRATION OF AN
ACCESS CONTROL, SURVEILLANCE AND
MONITORING SECURITY SYSTEM
(P.W. 710)**

**ISSUED
March 11, 2021**

**SUPPLEMENTAL INFORMATION
FOR THE INTEGRATION OF AN
ACCESS CONTROL, SURVEILLANCE AND
MONITORING SECURITY
P.W. 710**

Issued March 11, 2021

SELECTED RESPONSES TO REQUESTS FOR INFORMATION

1. **Question:** “Are you looking to replace the Brivo Access Control system software and panel equipment with a new access control system and keep all field devices (e.g. Readers, door contacts, request to exit devices, and lock hardware)? Or are you wanting to keep all equipment to include existing Brivo panels and looking to use a different software solution that will talk to the Brivo equipment? This second option may not be possible as I believe the Brivo panels are proprietary equipment and will not work on other software platforms.”

Answer: “We would like to use our existing system that is in place (Brivo and Eagle Eye).”

2. **Question:** “For the 24/7 live monitoring do you currently work with a monitoring company?”

Answer: “Yes, we have a 24/7 live monitoring company that monitors our system.”

3. **Question:** “What type of Intrusion system does the city currently use?”

Answer: “The City is currently using control panel type ACS6000 and ACS300.”

4. **Question:** “Is the Intrusion system integrated into the access control system via software or hardwired?”

Answer: “Intrusion is integrated to the access control system and hardwired.”