



BID NO. 968-0627-17A

## REMOVE/INSTALL GRANULAR ACTIVATED CARBON

### ADDENDUM NO. 1

A.) CHANGE TO PAGE 10, FILTER SAND PHYSICAL STANDARDS FOR SPECIFIC GRAVITY. WE WILL ADOPT AWWA B100-16, TABLE 1 LANGUAGE TO READ = SILICA SAND SPECIFIC GRAVITY >2.5

B.) TO CLARIFY ITEM 14 OF THE SCOPE, PLEASE NOTE THE FOLLOWING. COA FOR SAND MUST INCLUDE ANALYSIS OF SPECIFIC GRAVITY AND ACID SOLUBILITY.